



REVISIONS				
ZONE	LTR	DESCRIPTION	DATE	APPROVED
	0	PER NPS 66-1765-1768	11/15/66	DF
	A	REMOVED ENGRG. CONT PER REV NPS 66-1765-1768	7/14/67	RHW
	B	REV TITLE PER ECN PC-5545	12-6-68	RHW
	C	ADDED 50717-4 NPS 70-0004	1-21-70	FCY
	D	REVISED P-6293	4-17-70	FCY
	E	REVISED PER ECN P-6489	3-19-70	FCY
	F	ADDED 50717-5 NPS 75-1807	12-1-75	a 12-3-75
	G	REV PER G-1651	4/10/85	ppm
	H	OBsolete 48-5 G-2508	7/23/87	ppm

TABLE II

PART NO.	A	B	C	D	
50717-5	.675	.55 ±.003	1/2	1.762	OBsolete
50717-4	.531	.174 ±.003	11	1.630	
50717-3	.675	.390 ±.003	3/8	1.702	
50717-2		.328 ±.003	5/16		
50717-1	.531	.265 ±.003	1/4	1.630	
50717		.197 ±.003	10		

TABLE I

QTY REQD	DESCRIPTION	PART NO.	MATERIAL & FINISH
	WIRE TERMINAL	SEE TABLE II	INSERT: BRASS (MIL-C-50) TIN PL (MIL-T-10727) .0003 MIN THK BODY: COPPER (QQ-C-576) TIN PL (MIL-T-10727)

UNLESS OTHERWISE SPECIFIED DIM. ARE IN INCHES. TOLERANCES ON: DECIMALS ±.008 ANGLES ± 5°	CONTRACT NO. —	AMP AMP INCORPORATED HARRISBURG, PENNSYLVANIA
MATERIAL: SEE TABLE I	DR: <i>A. Youngblood</i> 11-11-66 CHK: <i>W. Swabell</i> 11-15-66 APPD: <i>W. Swabell</i> 11-16-66	
HEAT TREAT: —	DESIGN APPD: —	NAME: WIRE TERMINAL COPALUM-STRANDED/SOLID WIRE SIZE: #4AL-CU
FINISH: SEE TABLE I	OTHER APPD: —	SIZE: B CODE IDENT NO. 00779 NUMBER: 50717
AMP INFO: LOC: G B C		SCALE: 4:1 WT CALC ACTUAL SHEET 1 OF 1